



# TOWN OF PLYMOUTH

11 Lincoln Street  
Plymouth, Massachusetts 02360

(508) 747-1620

FAX (508) 830-4133

ADDENDUM 1

---

TO: Potential Bidders

FROM: Ashley Leaman, Procurement Assistant

DATE: November 23, 2016

RE: 21626, Water Meter and RF Module Installation

---

This addendum, consisting of two (2) pages, modifies the original bid document dated November 10, 2016. Please acknowledge receipt of this addendum in the space provided on the bid form. Failure to do so may subject the bidder to disqualification.

THE FOLLOWING CHANGES AND/OR ADDITIONS/DELETIONS MODIFIES THE BID DOCUMENT

1. Question: Item 4a are the 12,600 meters all inside? If yes, will the transmitter be mounted on the inside of structure or outside? If outside, is there existing wire or will contractor have to run new wire to outside of structure?

Answer: The Neptune self-contained solid state absolute encoder register, requires no wiring or mounting, except where a remote unit might be needed in a commercial building to move a remote closer to the exterior wall to allow radio signal communication.

2. What is the City's existing billing system?

Answer: Munis CIS.

3. Will Contractor be required to drill holes in lids for pit settings? If yes, what is the material of lids?

Answer: The Contractor will not be required to drill holes in the lids for pit settings.

END OF ADDENDUM 1